



# EMSL Analytical, Inc.

200 Route 130 North Cinnaminson, NJ 08077  
Tel/Fax: (800) 220-3675 / (856) 786-5974  
<http://www.EMSL.com> / [cinnaslab@EMSL.com](mailto:cinnaslab@EMSL.com)

EMSL Order: 041904405  
Customer ID: MICR65  
Customer PO:  
Project ID:

**Attention:** Chris Decker  
Micro Air Consulting ,LLC  
P.O.Box 908  
Greenville, MI 48838

**Phone:** (616) 302-0819  
**Fax:**  
**Received Date:** 02/16/2019 10:20 AM  
**Analysis Date:** 02/16/2019  
**Collected Date:** 02/15/2019

**Project:**

## Test Report: Asbestos Fiber Analysis by Transmission Electron Microscopy (TEM) Performed by EPA 40 CFR Part 763 Appendix A to Subpart E

Sample	Location	Volume (Liters)	Area Analyzed (mm <sup>2</sup> )	Non Asb	Asbestos Type(s)	#Structures		Analytical Sensitivity (S/cc)	Asbestos Concentration	
						≥0.5μ < 5μ	≥5μ		(S/mm <sup>2</sup> )	(S/cc)
NP-TEM-1 041904405-0001	Gym Storage Room	900.00	0.0910	0	None Detected	0	0	0.0047	<11.00	<0.0047

Analyst(s)  

---

Daniel Geoffroy (1)

  

---

Benjamin Ellis, Laboratory Manager  
or other approved signatory

EMSL maintains liability limited to cost of analysis. This report relates only to the samples reported above and may not be reproduced, except in full, without written approval by EMSL. EMSL bears no responsibility for sample collection activities or analytical method limitations. Interpretation and use of test results are the responsibility of the client. This report must not be used to claim product certification, approval, or endorsement by NVLAP, NIST, or any agency of the federal government. EMSL is not responsible for data reported in structures/cc, which is dependent on volume collected by non-laboratory personnel. Samples received in good condition unless otherwise noted. The test results meet the requirements of NELAC unless otherwise noted. Estimated accuracy, precision and uncertainty data available upon request.

Samples analyzed by EMSL Analytical, Inc. Cinnaminson, NJ NVLAP Lab Code 101048-0, AIHA-LAP, LLC-IHLAP Lab 100194, NYS ELAP 10872, NJ DEP 03036, PA ID# 68-00367

Initial report from: 02/16/2019 13:00 PM